



YOUR LOGO HERE

LIFE SAFETY INSPECTION

INSPECTION DATE:

TECHNICIAN:

- Make sure evacuation routes are posted in each room

- Check for obstructed exit routes

- Make sure severe weather shelters are identified

- Make sure all fire extinguishers have a current inspection tag

- Ensure all extinguishers have the green dial indication

- Make sure AEDs are unobstructed, clearly marked and operational

- Check AED battery for proper charge

- Make sure EXIT signs are clearly marked and operational

- Inspect all emergency lighting

- Make sure designated evacuation routes are illuminated

- Make sure eye wash stations are unobstructed, clearly marked and operational

- Make sure eyewash and emergency showers have a 15 minute water supply

- Submit safety procedures to Attorney General

- Submit record of safety drills to Attorney General

COMMENTS:

